14. Signature / Thumb impression of the Complainant / Informant

Noted in Ominal Complain

15. Date & Time of despatch to the court:

On of. 06. 21 at 11:00 may

Signature of the Officer-in-Charge, Police Station

Siliquiri Police Compassion Procedure & Station Rank: No. S. I of Palice & Matigana P.S

S. P. C

West Bengal State Electricity Distribution Company Limited (A Government of West Bengal Enterprise)

Registered Office:
Bidyut Bhavan, Block – DJ
Sector – II, Bidhannagar
Kolkata – 700 091
Website – www.wbsedcl.in
CIN – U40109WB2007SGC113473



Division Office: Siliguri Town Division Power House Complex, 2nd Mile, Sevoke Road, Siliguri Dist. Darjeeling. Pin. – 734001 E Mall – siliguritowndivision@gmail.com Tel. / Fax – 0353-2542863

Memo No: DM/STD/T-12/2|3

Date: 30.05.2021

To The Inspector-In-Charge P.S- Matigara

SUB: Intimation regarding a non-fatal electrical accident occurred on 29.05.2021 at about 15:50 Hrs at Chandmuni Bagan, near Siliguri Gate under the jurisdiction of Siliguri Town Division.

Sir,

I, Sri Soumyadeep Ganguly, S/O Sri Sibnath Ganguly posted as Assistant Engineer at Siliguri Town Division would like to inform you that an electrical accident occurred on 29.05.2021 at above mentioned time near Siliguri Gate – Chandmuni Bagan, Matigara. The name of the victim is Binod Barman, S/O Barendranath Barman of Prasannanagar- Belacoba, Dist-Jalpaiguri aged approx. 51 years- a hired labour of M/S Kallol Biswas – Saradamoni Road, Ashrampara, Siliguri- 734001, Dist-Darjeeling, who was carrying out the work of pole painting of new poles erected under IPDS Scheme.

As gathered from the site personnels the victim along with other labours went for carry out pole painting works in Police Line & Himachal Vihar 11 KV Feeders emanating from Ujanu 33/11 KV Sub Station on 29.05.2021. The said feeders were given shutdown early morning by HT Mobile Van Ujanu as per Shutdown requisition from M/S Kallol Biswas, who was entrusted to carryout pole painting works in the said feeders. They started to work at about 13:30 Hrs in Police Line feeder after the arrival of Site-In-Charge Sri Manojit Ghosh. Suddenly at around 15:50 Hrs, Pati Colony Feeder tripped from Ujanu Sub-Station. HT Mobile Van of Ujanu Sub Station, went for patrolling the said feeder when they came to know that after finishing work on Police Line Feeder the victim climbed on Pati Colony feeder for pole painting work which was LIVE. The victim got electrocuted as he had somehow touched the live line, then fell from the pole & received electrical as well as mechanical injuries. The victim was immediately taken to Shanti

This is for your kind information & necessary action please.

Received on 01/06/2021 at Sommyadeep Granguly
00/15hm wide CD FNO-02 D+ Assistant Engineer 30.05.2021
04/06/2021 and Stented Matigua MOB: 8900795049
PS Care NO 433/2021 Dt. 04/06/2021
MS 336 IPE and endonce to
05/15h Shoutignas for
1/5 immetignas

1/5 immetign