


West Bengal State Electricity Distribution Company Limited
(A Government of West Bengal Enterprise)

Registered Office :
Bidyut Bhavan, Block - DJ
Sector - II, Bidhannagar
Kolkata - 700 091
CIN - U40109WB2007SGC113473



Website - www.wbsecl.in

Matigara Customer Care Centre
Hospital more, Old Matigara Road,
Matigara, Darjeeling. Pin. - 734 010
E Mail - sm.matigara@gmail.com
Tel. - 03532571699/03532571054

MEMO NO: SM/CCCM/ADM/21-22/190

DATE: 30.06.2021

To
The Officer In Charge,
Matigara Police Station,
Matigara Thana More,
Matigara, pin-734010,
Darjeeling.

Sub: Information regarding non-fatal accident at premises of Sabita Mukherjee W/O Anjan Mukherjee during construction work of 3 storied building under Matigara CCC.

Sir

This is to inform you that after getting telephonic information the undersigned visited the place of incident. It has been found from local people of B.K Pally that on 30/06/2021 at about 12:00 pm one person named Gopal attended at the premises of Sabita Mukherjee W/O Anjan Mukherjee for building construction purpose. During the construction work, the said person got electrocuted from 440 VOLT overhead line as one iron rod suddenly touched the overhead 440 volt line. Due to this contact 2 nos of 440 volt line got damaged and power outage occurs. Building of Sabita Mukherjee W/O Anjan Mukherjee has been constructed in such a way that there is no safety distance from nearest 440 Volt line (0.5 meter from the building) and (0.4 meter from 11 KV Patiram Feeder).

According to local witnesses there was no power at that area for 60 min (approx.) after the accident and power was made available after our technical maintenance team cleared the electrical damage.

1. Place of accident: house of Sabita Mukherjee W/O Anjan Mukherjee, B.K Pally near 5th Mahananda Bridge, Patiram Jote, Matigara Dist.: Darjeeling.
2. Type: non fatal.
3. Victim: Gopal, name information collected from local witness
4. Injury: waist injury, information collected from local witness

After gathering full name of the victim, information will be provided from our end.

This is for your information and necessary action please.

Received on 01.07.2021 at 10:15h Yours faithfully

vide UDE NO 03 dt 01/07/2021 and

started Matigara PS case NO. 598/2021 dt 01/07/2021 MS

186 Electricity Act (Amendment 2007)

and endorsed to ASI Laxman

Saha. files. March 2021

Abhishek Roy
Station Manager
Matigara CCC
WBSEDCL.

30/06/21
PH: 8900705083
Assistant Engineer (Elec.) Station Manager