

2346

# FIRST INFORMATION REPORT

(Under Section 154 Cr. P.C.)

Dist. Jalpaiguri P.S. NTP Year 2021 FIR No. 1196/21 Date 04/11/2021

(i) Act IPC Sections 304A (ii) Act \_\_\_\_\_ Sections \_\_\_\_\_

(iii) Act \_\_\_\_\_ Sections \_\_\_\_\_ (iv) Others Acts & Sections \_\_\_\_\_

(a) Occurrence of Offence : Day Friday Date From 03/11/21 Date To 03/11/21

Time Period Day Hours Time From \_\_\_\_\_ Time To at 12:51 Hr.

(b) Information received at P.S. Date 04/11/2021 Time 16:55 Hr

(c) General Diary Reference : Entry No.(s) 151 Time 16:55 Hr

Type of Information : \_\_\_\_\_  
Place of Occurrence : (a) Direction and Distance from P.S. 0.3 km North / East Beat No. \_\_\_\_\_

(b) Address Sanya Sen Colony Block-A Pipkane P.S. NTP Jalpaiguri

(c) In case outside limit of this Police Station, then the Name of the P.S. N/A District N/A

Complainant / Informant : (a) Name Sri Subhadree Banerjee

(b) Father's / Husband's Name Sri Debasish Banerjee

(c) Date / Year of Birth : \_\_\_\_\_ (d) Nationality Indian

(e) Passport No. \_\_\_\_\_ Date of Issue : \_\_\_\_\_ Place of Issue \_\_\_\_\_

(f) Occupation Spt. Service

(g) Address Residential Engineer, NASEDC, Siliguri Town Division, Siliguri

Details of known / suspected / unknown accused with full particulars (Attach separate sheet, if necessary) : Ashin Kumar Banerjee / Odhuba Lal Banerjee of Sanya Sen Colony Block-A Siliguri.

Reasons for delay in reporting by the Complainant / Information

Particulars of properties stolen / involved (Attach separate sheet, if necessary) :

Total value of properties stolen / involved \_\_\_\_\_

Inquest Report / U.D. Case No. if any \_\_\_\_\_

FIR Contents (Attach separate sheets, if required) : The original written Complaint which is treated as FIR is reproduced over leaf of 4/11/21

Action taken : Since the above report reveals commissions of offence(s) as mentioned at item No. 2, registered the case and took up to the investigation / directed SI. Sanyamal Datta Roy of NTP A to take up

investigation / refused investigation / transferred to P.S. \_\_\_\_\_ on point of jurisdiction. FIR read over to the Complainant / Informant, admitted to be correctly recorded and a copy given to the Complainant / Informant free of cost.

Over the original written Complaint  
Signature / Thumb impression of the Complainant / Informant

Sanyamal  
4/11/21  
Signature of the Officer-in-Charge, Police Station

Date & Time of despatch to the court :

Name : SAMIR TAMANG  
Rank : SI OF POLICE No. : \_\_\_\_\_  
etc New Jalpaiguri P.S. S.P.

West Bengal State Electricity Distribution Company Limited  
(A Government of West Bengal Enterprise)

Registered Office:  
Bidyut Bhavan, Block - DJ  
Sector - II, Bidhannagar  
Kolkata - 700 091  
Website - www.wbsedcl.in  
CIN - U40109WB3007SGC113473



Division Office: Siliguri Town Division  
Power House Complex, 2<sup>nd</sup> Mile,  
Sevoke Road, Siliguri  
Dist. Darjeeling. Pin. - 734001  
E Mail - siliguritowndivision@gmail.com  
Tel. / Fax - 0353-2542863

Memo No: DM/STD/T-12/1111

Date: 04.11.2021

To  
The Inspector-In-Charge  
NJP P.S  
Siliguri

**SUB: F.I.R against Sri Ashis Kr. Banerjee S/O Dhurba Lal Banerjee of Surya Sen Colony Block-A, Siliguri in whose premises a fatal electrical accident occurred i.r.o Haradhan Mandal, S/O Lt. Akhil Mandal aged -23 years (approx.) resident of North Colony Gate Bazar, Siliguri under the jurisdiction of Siliguri Town Division.**

Sir,


I, Sri Subhadeep Banerjee, S/O Sri Debasish Banerjee posted as Divisional Engineer at Siliguri Town Division would like to inform you that on 03.11.21 at about 12:51 Hrs, a fatal electrical accident occurred in the premises of Sri Ashis Kr. Banerjee at Surya Sen Colony Block-A, Pipeline, Siliguri, Dist-Jalpaiguri. The name of the victim is Sri Haradhan Mandal S/O Lt. Akhil Mandal aged approx. 23 years who was assigned the job of fixing lights in the building of Sri Ashis Kr. Banerjee. The victim while fixing the lights accidentally/carelessly threw/dropped it over NBU-Deshbandhupara 33 KV live line leading to instant electrocution. The 33 KV feeder immediately tripped due to Earth Fault at NBU GSS end at 12:51 Hrs, after tripping of the line it was charged at 12:57 Hrs & stood ok.


It is to be mentioned here that the building of Sri Ashis Kr. Banerjee has unauthorized extension with very close proximity to our 33KV HT Overhead line. The minimum clearance from the live HT line should be 2.2 metres as per I.E rule. Moreover the activity carried out which led to the accident was also unauthorized.

This is for your kind information & necessary action please by treating this letter as F.I.R.

Encl: Photos of Accident Spot.

Received on 04/11/21 at 16:55 hrs vide  
NJP PS GOE NO 161 Dtd. 04/11/21. and  
Dated NJP PS Case No 1196/21 Dtd.  
04/11/21 U/S 304A IPC read over  
to SP Shyamal Deita for its  
investigation.

  
4/11/21  
Officer-in-Charge  
New Jalpaiguri Police Station  
Siliguri Metropolitan Police

  
4/11/21  
Divisional Engineer  
Siliguri Town Division  
MOB: 8900795048