



1. Dist. S.P.O. P.S. Margosa Year 2022 FIR No. 567/22 Date 14.05.2022
 2. (i) Act Sections (ii) Act Sections
 (iii) Act Sections (iv) Other Acts & Sections 133 (1) (a) (b) (c)
 3. [a] Occurrence of Offence : Day..... Date From 14.05.2022 Date To.....
 Time Period..... Time From 12:37 hrs Time To.....

[b] Information received at P.S. Date 14.05.2022 Time 22:35 hrs
 [c] General Diary Reference : Entry No. (s) 797 Time 22:35 hrs

4. Type of Information : Written / Oral :
 5. Place of Occurrence : (a) Direction and Distance from P.S. Beat No.
 [b] Address Males Math, Santipur, New Rangia, P.S. Margosa,
Dist. Darjeeling
 [c] In case outside limit of this Police Station, then the
 Name of the P.S. District X


6. Complainant / Informant :
 [a] Name Anil Kumar Kisku
 [B] Father's / Husband's Name
 [c] Date / Year of Birth [d] Nationality Indian
 [e] Passport No. Date of Issue Place of Issue
 [f] Occupation Assistant Engineer (B)
 [g] Address Subguri Suburban Division, N.B.S.E. O.C.

7. Details of known / suspected / unknown accused with full particulars
 (Attach separate sheet, if necessary):
Pra. nary. Kumar. Sinha (Consumer ID - 402042638, meter No.
BB-0280624) Males Math, Santipur, P.O. New Rangia, P.S. Margosa,
Dist. Darjeeling


8. Reasons for delay in reporting by the Complainant / Information

 9. Particulars of properties stolen / involved (Attach separate sheet, if necessary)

10. Total value of properties stolen / involved.....
 11. Inquest Report / U.D. Case No. If any.....

12. FIR Contents (Attach separate sheets, if required) The original written complaint
which is treated as FIR is reproduced overleaf 

13. Action taken : Since the above report reveals commission of offence (as mentioned in item No. 2,
 registered the case and took up the investigation / directed Asst. S.D. Chandu take up
 investigation / refuse investigation / transferred to P.S. on point of
 jurisdiction. FIR read over to the Complainant / Informant, admitted to be correctly recorded and a copy
 given to the Complainant / Informant free of cost.

14. Signature / Thumb impression of the Complainant / Informant
 Date & Time of despatch to the court Males Math original complaint
 Signature of the Officer-in-Charge, Police Station 
 Singur Police Commissionerate
 Name Anil Kumar Bhattacharya
 Rank S.D. Police No. AMC/PK



West Bengal State Electricity Distribution Company Limited
(A Government of West Bengal Enterprise)

Siliguri Sub-Urban Division Office, Shivmandir, Dist- Darjeeling
Pin-734011, Email- tech.suburban@gmail.com, Tel- 0353 2581005

Memo No - DM/SSD/T-12/21-22/

Date: 14.05.2022

Received on 14.05.2022 at 12.05 hrs vide GDE No. 798 of 14.05.2022

To
The Officer In Charge
Matigara Police Station
Matigara

and recorded
MTA No. 567/2022
of 14.05.2022,
u/s-135(1)(a)(b)
of Electricity
Act and
endorsed to
Asst. Avijit
Chandra
for its
verification.

Subject :- Intimation regarding tripping of 33KV line due to low clearance between 33KV line and building of Pranay Kumar Sinha ,Consumer ID-402042638, Meter No - BB0280624 near Halermatha, Santipur, PO-New Rangia, Darjeeling under Siliguri Sub-Urban Division.

14.05.22

Officer In-charge
Matigara Police Station
Siliguri Police Commission

Sir
This is to inform you that Pranay Kumar Sinha Consumer ID-402042638 Meter No - BB0280624 near Halermatha, Santipur, PO-New Rangia has been allotted for electrical connection. A 33 KV(NBU-Bengdubi) line is passing over the house. At the time of application there was sufficient gap between 33 KV OH line and house based on which electrical connection was provided that house. Subsequently the owner of the house built another 2 floor without seeking permission from WBSIEDCL.

Station gathered from the HT Mobile van of NBU 132/33/11 KV substation that NBU-Bengdubi 33 KV line tripped around 12:37 PM. While petrolling the line they saw 33KV feeder distance from the roof of the building is very low and also a flag is hoisted over the roof. The flag fell on the 33 KV line due to strong winds. As a result the 33 KV feeder (NBU-Bengdubi 33KV Feeder-NBU 132/33/11 KV Substation) leading to huge sparking & tripping occurred of the said NBU-Bengdubi 33 KV feeder. Due to this such kind tripping it is causing unnecessary inconvenience to bonafide consumers ie Hospital situated inside Bengdubi army camp.

It may be stated here such kind of construction in the close vicinity to our live lines is totally unauthorized & condemnable by law. As the work was being carried out in such a casual manner, such incident would have been taken place. Such kind of mal practices leads to fatal accidents. Hence you are requested to take necessary action accordingly. Thanking you.

- Enclou:
1. Pictures of that building.

MATIGARA PS / SPC
GDE No. 798 Date 14/05/22
Duty Officer

Anil Kumar Kisku
14/05/2022
(Anil Kumar Kisku)
Assistant Engineer (E)
Siliguri Sub-Urban Division
WBSIEDCL
Mob No-8900795080